

Lead in Drinking Water Analytical Results Summary
 Syracuse Academy of Science Elementary School
 4837 S. Salina St, Syracuse, New York

School / Sample Identification #	Date/Time Collected	Sample Location	Total Lead (ug/L)
SAS-ES-1	4/18/2025 10:04	Drinking Fountain Cafeteria	<1.0
SAS-ES-2	4/18/2025 10:05	Kitchen 3 Bay	<1.0
SAS-ES-3	4/18/2025 10:06	Kitchen Hand Wash	<1.0
SAS-ES-4	4/18/2025 10:08	Boy's Restroom Cafeteria (Left)	<1.0
SAS-ES-5	4/18/2025 10:09	Boy's Restroom Cafeteria (Right)	<1.0
SAS-ES-6	4/18/2025 10:10	Girl's Restroom Cafeteria (Left)	2.4
SAS-ES-7	4/18/2025 10:11	Girl's Restroom Cafeteria (Right)	<1.0
SAS-ES-8	4/18/2025 10:14	Drinking Fountain Gym	<1.0
SAS-ES-9	4/18/2025 10:18	201 - Restroom	7.0
SAS-ES-10	4/18/2025 10:20	207 - Restroom	4.8
SAS-ES-11	4/18/2025 10:21	206 - Nurse's Restroom	2.3
SAS-ES-12	4/18/2025 10:25	202 - Restroom	1.5
SAS-ES-13	4/18/2025 10:24	202 - Classroom Sink	1.5
SAS-ES-14	4/18/2025 10:28	Boy's Restroom next 202 (Left)	3.0
SAS-ES-15	4/18/2025 10:29	Boy's Restroom next 202 (Middle)	3.9
SAS-ES-16	4/18/2025 10:30	Boy's Restroom next 202 (Right)	3.6
SAS-ES-17	4/18/2025 10:31	Girl's Restroom next 203 (Left)	3.2
SAS-ES-18	4/18/2025 10:32	Girl's Restroom next 203 (Middle)	2.5
SAS-ES-19	4/18/2025 10:33	Girl's Restroom next 203 (Right)	2.8
SAS-ES-20	4/18/2025 10:34	202/203 - Staff Restroom	<1.0
SAS-ES-21	4/18/2025 10:36	Drinking Fountain next 202/203	<1.0
SAS-ES-22	4/18/2025 10:37	Bottle Fountain next 202/203	<1.0
SAS-ES-23	4/18/2025 10:44	Boy's Restroom next 301 (Left)	3.4
SAS-ES-24	4/18/2025 10:45	Boy's Restroom next 301 (Middle)	3.5
SAS-ES-25	4/18/2025 10:46	Boy's Restroom next 301 (Right)	5.8
SAS-ES-26	4/18/2025 10:47	Girl's Restroom next 302 (Left)	5.0
SAS-ES-27	4/18/2025 10:48	Girl's Restroom next 302 (Middle)	5.6
SAS-ES-28	4/18/2025 10:44	Girl's Restroom next 302 (Right)	3.8
SAS-ES-29	4/18/2025 10:50	302/303 - Staff Restroom	3.0
SAS-ES-30	4/18/2025 10:51	Drinking Fountain next 301/302	<1.0
SAS-ES-31	4/18/2025 10:52	Bottle Fountain next 301/302	<1.0
SAS-ES-33	4/18/2025 11:03	Boy's Restroom next 101 (Middle)	<1.0
SAS-ES-34	4/18/2025 11:09	Girl's Restroom next 101 (Left)	<1.0
SAS-ES-35	4/18/2025 11:10	Girl's Restroom next 101 (Middle)	<1.0
SAS-ES-36	4/18/2025 11:11	Staff Restroom next 101	<1.0
SAS-ES-37	4/18/2025 11:14	Drinking Fountain next 101/102	<1.0
SAS-ES-38	4/18/2025 11:15	Bottle Fountain next 101/102	<1.0
SAS-ES-39	4/18/2025 11:17	101 - Classroom Sink	<1.0

Notes:

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)