

## Lead in Drinking Water Analytical Results Summary

Syracuse Academy of Science High School

1001 Park Ave, Syracuse, New York

School / Sample Identification #	Date/Time Collected	Sample Location	Total Lead (ug/L)
SAS-HS- 1	4/17/2025 08:32	Main Office Kitchen Sink	3.0
SAS-HS- 2	4/17/2025 08:33	Drinking Fountain Basement	<1.0
SAS-HS- 3	4/17/2025 08:34	Bottle Fountain Basement	1.9
SAS-HS- 4	4/17/2025 08:37	102 - Teacher's Lounge Sink (Left)	1.9
SAS-HS- 5	4/17/2025 08:38	102 - Teacher's Lounge Sink (Right)	<b>11.1</b>
SAS-HS- 6	4/17/2025 08:40	Drinking Fountain next 102	<1.0
SAS-HS- 7	4/17/2025 08:41	Drinking Fountain next 102	<1.0
SAS-HS- 8	4/17/2025 08:43	108 - Girl's Restroom	4.9
SAS-HS- 9	4/17/2025 08:45	108 - Boy's Restroom (Left)	<1.0
SAS-HS- 10	4/17/2025 08:46	108 - Boy's Restroom (Middle)	<1.0
SAS-HS- 11	4/17/2025 08:47	108 - Boy's Restroom (Right)	<1.0
SAS-HS- 12	4/17/2025 08:50	Basement Boy's Restroom near Exit B (Right)	<b>143</b>
SAS-HS- 13	4/17/2025 08:51	Basement Boy's Restroom near Exit B (Left)	3.1
SAS-HS- 14	4/17/2025 08:52	Sacred Heart Food Storage	<b>16.1</b>
SAS-HS- 15	4/17/2025 09:01	109 - Classroom Sink	1.5
SAS-HS- 16	4/17/2025 09:03	111 - Restroom near Cafeteria	<b>5.5</b>
SAS-HS- 17	4/17/2025 09:05	Boy's Restroom	1.6
SAS-HS- 18	4/17/2025 09:07	Girl's Restroom (Left)	3.3
SAS-HS- 19	4/17/2025 09:08	Girl's Restroom (Right)	3.7
SAS-HS- 20	4/17/2025 09:10	Staff Restroom	1.6
SAS-HS- 21	4/17/2025 09:12	Kitchen Dishwasher	<b>12.6</b>
SAS-HS- 22	4/17/2025 09:13	Kitchen - 2 Bay	1.2
SAS-HS- 23	4/17/2025 09:14	Kitchen Food Prep Island	1.4
SAS-HS- 24	4/17/2025 09:15	Kitchen Food Prep near Stove	1.3
SAS-HS- 25	4/17/2025 09:18	Kitchen Staff Restroom	1.1
SAS-HS- 26	4/17/2025 09:25	Boy's Locker room Bathroom (Left)	<b>6.6</b>
SAS-HS- 27	4/17/2025 09:26	Boy's Locker room Bathroom (Right)	3.5
SAS-HS- 28	4/17/2025 09:27	Drinking Fountain Boy's Locker room	1.3
SAS-HS- 29	4/17/2025 09:28	Boy's Locker room Bathroom Sink	<b>5.3</b>
SAS-HS- 30	4/17/2025 09:30	Girl's Locker room Bathroom Sink	1.7
SAS-HS- 31	4/17/2025 09:31	Drinking Fountain Girl's Locker room	1.2
SAS-HS- 32	4/17/2025 09:32	Girl's Locker room Coach's Bathroom	<b>23.2</b>
SAS-HS- 33	4/17/2025 09:35	Drinking Fountain Gym	<1.0
SAS-HS- 34	4/17/2025 09:36	Bottle Fountain Gym	1.3
SAS-HS- 35	4/17/2025 09:42	Girl's Restroom next 210 (Left)	1.7
SAS-HS- 36	4/17/2025 09:43	Girl's Restroom next 210 (Right)	1.1
SAS-HS- 37	4/17/2025 09:47	Boy's Restroom next 210 (Left)	5.0
SAS-HS- 38	4/17/2025 09:48	Boy's Restroom next 210 (Middle)	<b>29.6</b>
SAS-HS- 39	4/17/2025 09:49	Boy's Restroom next 210 (Right)	<b>9.5</b>
SAS-HS- 40	4/17/2025 09:51	202A - Restroom	1.6
SAS-HS- 41	4/17/2025 09:53	Drinking Fountain next 202A	3.4
SAS-HS- 42	4/17/2025 09:54	Bottle Fountain next 202A	4.3
SAS-HS- 43	4/17/2025 09:56	202 - Classroom Sink	3.8
SAS-HS- 44	4/17/2025 09:58	302 - Classroom Sink	<b>6.4</b>
SAS-HS- 45	4/17/2025 10:00	302A - Restroom	3.7
SAS-HS- 46	4/17/2025 10:01	Drinking Fountain next 302A	3.7
SAS-HS- 47	4/17/2025 10:02	Bottle Fountain next 302A	<b>6.0</b>
SAS-HS- 48	4/17/2025 10:05	Drinking Fountain next 308	<1.0
SAS-HS- 49	4/17/2025 10:07	309A - Restroom	4.1

## Notes:

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)