

Lead in Drinking Water Analytical Results Summary
 Syracuse Academy of Science Middle School
 200 W. High Terrace, Syracuse, New York

School / Sample Identification #	Date/Time Collected	Sample Location	Total Lead (ug/L)
SAS-MS-1	4/18/2025 08:18	102 - Nurse Room	2.5
SAS-MS-2	4/18/2025 08:19	Drinking Fountain next 102	<1.0
SAS-MS-3	4/18/2025 08:20	Bottle Fountain next 102	<1.0
SAS-MS-4	4/18/2025 08:21	Restroom sink next 102	1.3
SAS-MS-5	4/18/2025 08:23	Men's Restroom next Equipment Room (left)	3.5
SAS-MS-6	4/18/2025 08:24	Men's Restroom next Equipment Room (right)	6.1
SAS-MS-7	4/18/2025 08:28	Women's Restroom next Equipment Room (left)	5.5
SAS-MS-8	4/18/2025 08:29	Women's Restroom next Equipment Room (right)	1.9
SAS-MS-9	4/18/2025 08:31	Kitchen Hand Wash sink	<1.0
SAS-MS-10	4/18/2025 08:32	Kitchen 3-bay sink	<1.0
SAS-MS-11	4/18/2025 08:38	Drinking Fountain next 112	<1.0
SAS-MS-12	4/18/2025 08:48	216 - Classroom sink	<1.0
SAS-MS-13	4/18/2025 08:49	215 - classroom sink	18.7
SAS-MS-14	4/18/2025 08:51	Men's restroom next 215 (left)	1.9
SAS-MS-15	4/18/2025 08:52	Men's restroom next 215 (right)	1.3
SAS-MS-16	4/18/2025 08:56	Drinking fountain next 214	<1.0
SAS-MS-17	4/18/2025 08:57	Bottle fountain next 214	<1.0
SAS-MS-18	4/18/2025 09:00	210 - Classroom sink	33.4
SAS-MS-19	4/18/2025 09:02	Women's Restroom next 210 (left)	<1.0
SAS-MS-20	4/18/2025 09:03	Women's Restroom next 210 (middle)	<1.0
SAS-MS-21	4/18/2025 09:04	Women's Restroom next 210 (right)	<1.0
SAS-MS-22	4/18/2025 09:05	Drinking fountain next 208	<1.0
SAS-MS-23	4/18/2025 09:06	Bottle fountain next 208	<1.0
SAS-MS-24	4/18/2025 09:09	208 - Staff lounge restroom sink	<1.0
SAS-MS-25	4/18/2025 09:10	208 - Staff lounge kitchen sink	<1.0
SAS-MS-26	4/18/2025 09:13	204 - Restroom sink	2.5
SAS-MS-27	4/18/2025 09:21	Women's restroom - Gym Lobby (left)	4.6
SAS-MS-28	4/18/2025 09:22	Women's restroom - Gym Lobby (right)	14.0
SAS-MS-29	4/18/2025 09:23	Men's restroom - Gym Lobby (left)	8.8
SAS-MS-30	4/18/2025 09:24	Men's restroom - Gym Lobby (right)	5.0

Notes:

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)